

## B.Tech II Year II Semester (R13) Supplementary Examinations December/January 2015/2016 **ELECTRICAL MACHINES – II**

## (Electrical and Electronics Engineering)

Time: 3 hours Max. Marks: 70

## PART - A

(Compulsory Question)

\*\*\*\*

1 Answer the following:  $(10 \times 02 = 20 \text{ Marks})$ 

- (a) Distribution transformers are always designed for lower magnetic losses. Why?
- (b) For a load of same magnitude, the efficiency of a transformer will be more for 0.8 leading power factor load than 0.8 lagging power factor load. Comment.
- (c) Give the factors affecting the load sharing among the transformers operating in parallel.
- (d) Comment on the size, efficiency and voltage regulation of autotransformer and a two winding transformer.
- (e) Why a bank of single phase transformers connected in delta is preferred over a three phase delta connected transformer?
- (f) A 3-phase, 50 Hz squirrel cage induction motor runs at 4% slip. What will be frequency of rotor currents?
- (g) What is Cogging in an induction motor?
- (h) The starting current and starting torque of induction motor increases with decrease in supply frequency. How is the starting current and starting torque related to the supply frequency?
- (i) In what ratio the line current and starting torques are reduced with star-delta starting?
- (j) On what factors does the speed of a induction motor depend?

## PART - B

(Answer all five units,  $5 \times 10 = 50 \text{ Marks}$ )

UNIT – I

- 2 (a) With relevant phasor diagrams, explain the operation of a practical single phase transformer operating on lagging and leading power factor loads.
  - (b) A single phase 50 Hz transformer has 440 turns on the primary and 110 turns on the secondary winding takes a no-load current of 5 A at 0.2 power factor lagging. If the secondary supplies a current of 120 A at a power factor of 0.8 lagging. Estimate the current taken by the primary. Take secondary voltage as reference.

OR

- 3 (a) In a transformer, derive the condition for maximum efficiency and thus find the load current at which the efficiency is maximum.
  - (b) A 200 kVA 1-phase transformer is in operation continuously. For 8 hours in a day, the load is 160 kW at 0.8 pf. For 6 hours, the load is 80 kW at unity pf and for the remaining period of 24 hours it runs on no-load. Full-load copper losses are 3.02 kW and the iron losses are 1.6 kW. Find all-day efficiency.

UNIT – II

- 4 (a) Derive an expression for saving of copper when an autotransformer is used.
  - (b) Obtain the approximate equivalent circuit of a 200 / 2000 V single-phase 30 kVA transformer referred to 200 V side using the following test results:

OC Test:	200 V	6.2 A	360 W	on I.v. side
SC Test:	75 V	18 A	600 W	on h.v. side

OR

- 5 (a) Two transformers operating in parallel have different reactance to resistance ratios. Show that one transformer operates at a better power factor than the other.
  - (b) With a neat circuit diagram, describe back-to-back test conducted on two identical transformers.

Contd. in page 2

www.FirstRanker.com

UNIT - III

6 Explain Scott connection with neat diagrams. With necessary phasor diagrams, prove that a threephase system can be established from a two-phase system using T-T connection.

OR

- 7 (a) Explain with the help of suitable diagrams, how rotating magnetic field is produced in a 3-phase induction motor.
  - (b) Why the air-gap between stator core and rotor is made as small as possible?

UNIT - IV

- 8 (a) Establish a relation between full load torque and maximum torque of a three phase induction motor.
  - (b) A 6-pole, 3-phase, 50 Hz induction motor develops maximum torque of 300 N-m at a speed of 960 rpm. Determine the torque developed by the motor at 5% slip. The rotor resistance per phase is 0.6 ohm.

OR

- 9 (a) Describe the principle of operation of three phase induction motor. What are the operational similarities and differences between transformers and induction motors?
  - (b) The power input to the rotor of a 440 V, 50 Hz, 3-phase, 6-pole induction motor is 50 kW. It is observed that the rotor e.m.f makes 120 complete cycles per minute. Calculate: (i) Slip. (ii) Rotor speed. (iii) Rotor copper loss/phase. (iv) Rotor resistance per phase.

UNIT – V

- 10 (a) Explain the consequent pole technique for controlling speed of three phase induction motor.
  - (b) Explain the cascade arrangement for controlling the speed of three phase induction motor. Derive the equation for speeds at which the cascade set operates.

OR

- 11 (a) List out the merits and demerits of rotor resistance control over other methods of controlling the speed of three phase induction motor.
  - (b) With a neat sketch, explain the operation of star-delta starter. Also, mention its limitations.