

GUJARAT TECHNOLOGICAL UNIVERSITY
BE - SEMESTER-VIII (NEW) - EXAMINATION – SUMMER 2018
Subject Code: 2183507
Date: 04/05/2018
Subject Name: Design of Treatment Plants
Time: 10:30 AM to 01:00 PM
Total Marks: 70
Instructions:

1. Attempt all questions.
2. Make suitable assumptions wherever necessary.
3. Figures to the right indicate full marks.

- Q.1 (a)** The catchment area is of 200 hectares. The surface cover in the catchment can be classified as given below. **07**

| Type of cover | Coefficient of runoff | Percentage |
|-------------------------|-----------------------|------------|
| Roofs | 0.90 | 15 |
| Pavements and Yards | 0.80 | 15 |
| Lawns and Gardens | 0.15 | 25 |
| Roads | 0.40 | 20 |
| Open grounds | 0.10 | 15 |
| Single family dwellings | 0.50 | 10 |

Calculate the runoff coefficient and quantity of storm water runoff, if intensity of rainfall is 30mm/hr for rain with duration equal to time of concentration. If population density in the area is 350 person /hectare and rate of water supply is 200 LPCD, calculate design discharge for separate system, partially separate system and combined system.

- (b)** Explain philosophy of water quality between sources and sink for surface water sources. **07**

- Q.2 (a)** Determine the terminal settling velocity for a sand particle with an average diameter of 0.5 mm and a density of 2600 kg/m³ settling in water at 20°C. Density and viscosity values are as $\rho_w = 998 \text{ kg/m}^3$, $\mu = 1.003 \times 10^{-3} \text{ N.s/M}^2$ and Shape factor is $\phi = 0.85$. **07**

- (b)** Design a continuous flow stir tank reactor (ASP) to treat 20 MLD domestic wastewater. BOD₅ of settled waste water to the reactor is 200mg/l and desired BOD of treated effluent is 30 mg/l. Assume that plant is operated at following conditions. **07**

- 1) Peak flow rate = 2.5 × daily average flow.
- 2) Influent biomass concentration, $X_0 = 0.0 \text{ mg/l}$
- 3) MLVSS in the reactor, $X = 3500 \text{ mg/l}$
- 4) Recycled Sludge, $X_r = 10000 \text{ mg/l}$
- 5) MLVSS is 80% of MLSS
- 6) Design Mean cell residence time, $\theta_c = 10\text{d}$
- 7) Effluent contains 25 mg/l of biological solids of which 65% is biodegradable.
- 8) BOD₅ is 68% of UBOD
- 9) BOD rate constant $K = 0.1 \text{ per day}$, $Y = 0.5$, $K_d = 0.06\text{d}^{-1}$

OR

- (b)** Write a note on different technique of scale up before commercial treatment plant inception. **07**

- Q.3 (a)** Using Rankin's equation, determine the treatment efficiency of a two stage trickling filter system designed for the following conditions. **07**
- 1) Average waste water flow, $Q_0 = 1000 \text{ m}^3/\text{d}$
 - 2) Concentration of applied $\text{BOD}_5 = 250 \text{ mg/l}$
 - 3) Volume of first stage filter, $V_1 = 800 \text{ m}^3$
 - 4) Filter Depth, $D = 2 \text{ m}$.
- (b)** Write a short note on Grit Chamber. **07**
- OR**
- Q.3 (a)** Waste water flow of $0.60 \text{ m}^3/\text{min}$ containing 150 mg/l of oil and grease is to be reduced to a concentration of 25 mg/l . Assume the following given data, design a dissolved air floatation system. **07**
- Surface loading rate, $\text{SLR} = 10 \text{ l/m}^2 \text{ min}$.
 Sludge Flow rate, $Q = 0.6 \text{ m}^3/\text{min}$
 Waste Water Temperature = 35°C
 Air Solubility at 35°C , $S_a' = 17.15 \text{ ml/L}$
 Air to Solid ratio, $A/S = 0.025 \text{ ml/mg}$
 Fraction of air saturation, $f = 0.80$
 Recycle system pressure = 500 kPa
- (b)** Write a short note on ZLD in Pharmaceutical Industry. **07**
- Q.4 (a)** Design a single effect evaporator for following design criteria. **07**
- 1) Total Number of Effects = 1
 - 2) Feed Flow Rate = 2000 kg/hr
 - 3) Caustic Soda Inlet Concentration = 0.25 mg/l
 - 4) Caustic Soda Outlet Concentration = 0.3 mg/l
 - 5) Steam Temperature = 100°C
 - 6) Feed Temperature = 25°C
 - 7) Temperature of product = 95°C
 - 8) Assume Steam Economy, $\text{SE} = 3.5$
 - 9) Latent Heat of steam at feed, $\lambda_S = 539.92 \text{ Kcal/Kg}$
 - 10) Latent Heat of Evaporate, $\lambda_E = 546.22 \text{ Kcal/Kg}$
 - 11) Specific heat of condensate, $\text{CC} = 1.004 \text{ Kcal/Kg. }^\circ\text{C}$
 - 12) Specific heat of Feed, $\text{CF} = 0.95 \text{ Kcal/kg. }^\circ\text{C}$
 - 13) Specific heat of product, $\text{CP} = 0.91 \text{ Kcal/kg. }^\circ\text{C}$
- (b)** Explain Multieffect Evaporator and determine its rate equation and enthalpy equation for forward feed, three effects. **07**
- OR**
- Q.4 (a)** Assume suitable design criteria; design an aerated grit chamber for an average municipal waste water flow of 10 MLD . (Assuming the peaking factor as 2.5, depth of the tank 2 m , width to depth ratio of 1.5:1, air supply rate $0.3 \text{ m}^3/\text{min.m}$ and assume that 0.015 m^3 of grit settles per 1000 m^3 of flow.) **07**
- (b)** Explain factors affecting the water demand for sewage water treatment plant. **07**
- Q.5 (a)** Design an activated carbon Column for sieve size of 0.9 mm of GAC. The liner velocity is 10 m/hr , and pressure drop is 30 mbar , Pressure drop in disc is 3.5 mbar for 30 mm disc size and factor of correction is 4.30 for original size of disc. **07**
- (b)** Explain mechanism of secondary clarifier. **07**
- OR**
- Q.5 (a)** Write a note on storm water. **07**
- (b)** Explain coagulation and flocculation. **07**
